

April 02, 2026

---

## ADDENDUM NO. 1

**PROPOSAL FOR FURNISHING ALL LABOR, MATERIALS, EQUIPMENT, TRANSPORTATION, SUPERVISION, PERMITS, ETC. NECESSARY FOR THE ANGELLE HALL CONTROLS UPGRADE (01-107-24-05, CEA #246), LOCATED AT THE UNIVERSITY OF LOUISIANA AT LAFAYETTE CAMPUS, IN LAFAYETTE, LOUISIANA.**

---

**Due Tuesday, April 07, 2026 – 2:00 PM Solicitation No.26209**

The following is to be made part of the original specifications as though issued at the same time and shall be incorporated integrally therewith. This addendum shall be acknowledged **on the BID FORM** when submitted to the Purchasing Department prior to the bid due date/time.

---

**Item No. 1 – General:**

1. See attached pre-bid sign in sheet.

**Item No. 2 – Changes to Specifications:**

2. Reference Section 23 90 20 – Temperature Controls, Page 47 of 48, Subsection 1.3 Scope, Item C, Equipment. Add Item No. 6 to read as follows. “For Percussion Area DX Split Equipment (total of 2), replace existing controller and associated sensors. Replace existing wiring as required and/or if needed to accommodate new sensors. Existing thermostats to remain.”

**Item No. 3 – Contractor Questions:**

3. Question – Are we changing the sensors and controls on the air handlers?  
Response – Yes. The intended scope is to replace existing controllers associated with referenced equipment including sensors.
4. Question – Do we change safety devices?  
Response – No. All safety devices to remain.

---

This is a public works bid. The addendum **MUST** be acknowledged with your bid **on** the BID FORM. For questions related to bidding these projects, please contact the UL Lafayette Purchasing Department at [bidquestions@louisiana.edu](mailto:bidquestions@louisiana.edu) or 337.482.9051.

Kristi Montet  
Director, Procurement and Travel  
University of Louisiana at Lafayette  
Department of Purchasing



UNIVERSITY OF  
**LOUISIANA**  
LAFAYETTE

PJD  
mb

SOLICITATION FILE NO. ~~26209~~ corrected -26209 / R1629624 BID DUE DATE/TIME: 4/7/2026 @ 2:00 PM

BID FILE TITLE ANGELLE HALL CONTROLS UPGRADE (01-107-24-05, CEA #246)

PRE-BID MEETING HELD: 3/30/2026 at 9:00 AM LOCATION: PARKER HALL, UL CAMPUS

FACILITATED/CONDUCTED BY: PHILLIP J. DUPLECHIN, PE

THE FOLLOWING INDIVIDUALS WERE IN ATTENDANCE FOR THE PRE-BID MEETING  
(Please Write Legibly.)

NAME (First & Last)	COMPLETE BUSINESS NAME	EMAIL ADDRESS
1. Darrell Boudreaux	CSE W-Industries Select Building Controls	darrell_boudreaux@w-industries.com
2. Jordan Dupre	CSE W-Industries Select Building Controls	Jordan_Dupre@w-industries.com
3. Michael Skute	Powers & Louisiana	michael.skute@powers-lvnae.com
4. Jody Bourque	Powers	jody.bourque@powers-hvac.com
5. Jayden Gladney	UL Lafayette	Jayden.Gladney1@louisiana.edu
6. Stephen Crutcher	UL Lafayette	stephen.crutcher@louisiana.edu
7. Jeremie Constant	UL Lafayette	jeremie.constant@louisiana.edu
8. Joey Spaetgen	UL Lafayette	Henry.Spaetgen@louisiana.edu
9. Kendal Fontenot	UL Lafayette	Kendal.Fontenot@louisiana.edu
10. Mary Borel	UL Lafayette	
Mary Jo Adams	UL Lafayette	