

**May 14, 2026**

---

**ADDENDUM NO. 2**

**PROPOSAL FOR FURNISHING ALL LABOR, MATERIALS, EQUIPMENT, TRANSPORTATION, SUPERVISION, PERMITS, ETC. NECESSARY FOR THE NIRC – BUILDING 10B 1<sup>ST</sup> FLOOR INTERIOR MODIFICATIONS, LOCATED AT THE UNIVERSITY OF LOUISIANA AT LAFAYETTE CAMPUS, IN NEW IBERIA, LOUISIANA.**

---

**Due Tuesday, May 19, 2026 – 2:00 PM Solicitation No.26211**

The following is to be made part of the original specifications as though issued at the same time and shall be incorporated integrally therewith. This addendum shall be acknowledged **on the BID FORM** when submitted to the Purchasing Department prior to the bid due date/time.

---

**Item No. 1 – Changes to Specifications:**

1. Reference Section 08 11 13, Interior Standard Steel Doors and Frames, page 2 of 7, Item 2, Frames, Change Construction type from “full profile welded”, to “knock down type frames”.
2. Reference Section 08 11 13, Exterior Standard Steel Doors and Frames, page 3 of 7, Item 2, Frames, Change Construction type from “full profile welded”, to “knock down type frames”.

**Item No. 2 – Contractor Questions:**

3. Question – Are any door locations fire rated?  
Answer – Doors are **NOT** fire rated.
4. Question – What are the lock functions?  
Answer –

B01 – (Existing to Remain)	B08 – (Storeroom)
B02 – (Storeroom)	B09 – (Storeroom)
B03 – (Storeroom)	B10 – (Classroom)
B04 – (Storeroom)	B11 – (Storeroom)
B05 – (Storeroom)	B12 – (Storeroom)
B06 – (Storeroom)	B13 – (Storeroom)
B07 – (Classroom)	
5. Question – In the hardware specifications it describes the keying scenarios, but at the very bottom of page 5/10 it states in section 2.7; “Keying” A. Owner furnish and owner installed. So, do we just provide construction cores and keys, or do we also provide permanent cores and keying as listed?  
Answer – Remove all references to Owner furnish and Owner installed for locksets. All locksets to be provided and installed by contractor. Provide standard, removable, 7-pin core (with blank key) to be keyed by owner. Contractor shall coordinate meeting with owner to determine keying order for building.



**Purchasing Office**

P.O. Box 40197 • Lafayette, LA 70504-0197

Office: (337) 482-5396

Fax: (337) 482-5059

6. Question – If we do provide permanent cores, will they be keyed to the existing system as stated in D. 3?  
Answer – Contractor shall coordinate meeting with owner to determine keying order for building.
- 

This is a public works bid. The addendum **MUST** be acknowledged with your bid **on** the BID FORM. For questions related to bidding these projects, please contact the UL Lafayette Purchasing Department at [bidquestions@louisiana.edu](mailto:bidquestions@louisiana.edu) or 337.482.9051.

Kristi Monet, NIGP-CPP  
Director, Procurement and Travel  
University of Louisiana at Lafayette  
Department of Purchasing